

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

		1. CONTRACT ID CODE		PAGE OF PAGES 1 2	
2. AMENDMENT/MODIFICATION NO. 002		3. EFFECTIVE DATE June 5, 2008		4. REQUISITION/PURCHASE REQ. NO.	
		5. PROJECT NO. (If applicable)			
6. ISSUED BY ARCHITECT OF THE CAPITOL United States Capitol Washington, D.C. 20515			7. ADDRESS AMENDMENT/MODIFICATION TO Architect of the Capitol Procurement Division Ford House Office Building Attn: John Friedhoff Room H2-263 Second and "D" Streets, S.W. Washington, DC 20515		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			(X)	9A. AMENDMENT OF SOLICITATION NO. RFP080040	
				9B. DATED (See Item 11) 5/7/2008	
				10A. MODIFICATION OF CONTRACT/ORDER NO.	
CODE		FACILITY CODE		10B. DATED (See Item 13)	
SUBJECT: Annual Maintenance for Electrical Equipment					

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

<p>The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of offers is not extended.</p> <p>Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:</p> <p>(a) By completing Items 8 and 15, and return <u>1</u> copy of the amendment; (b) By acknowledging receipt of this amendment in Block 12 of Page 1 of the solicitation package, giving amendment number and its date; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter make reference to the solicitation and this amendment, and is received prior to the opening/receipt hour and date specified.</p>
12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT/ORDER NO. IN ITEM 10A.			
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).			
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:			
D. OTHER (Specify type of modification and authority)			
E. IMPORTANT: Contractor is required to sign this document and return it to the issuing office.			
14. DESCRIPTION OF AMENDMENT/MODIFICATION 1. SEE CONTINUATION PAGES. Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.			
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
_____ (Signature of person authorized to sign)		By _____ (Signature of Contracting Officer)	

The following questions are shown with the Government responses below:

- YES-Attachment A, page 4, for low voltage air breakers, please clarify whether primary injection or secondary testing is acceptable.
- No Resisters-Attachment A, page 21 Electrical tests, item 9 requests testing the neutral grounding equipment. Are all neutrals grounded through a resistor?
- Test at Min. and Max.-Attachment B, items 001, 003, 004 etc. Reference is made to testing medium voltage breakers at minimum and maximum control voltage, which we do with a separate rectified power supply and rheostat. Then the requirement suggests testing with local control power, which will not be minimum and maximum, but rather the DC control bus value only. Please clarify if each breaker is to be tested at minimum and maximum control voltage, or only the DC control bus value.

Distribution:

Contract File
COTR -

